

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Letter No. - 455

Dated: - 27.07.2026

It is certified that an inspection team headed by Assistant Engineer (Public Health), Bhojpur from Public Health Engineering Department (PHED), Bhojpur, Bihar-802206 inspected the Mother Teresa Public School, Dularpur, Ara, Bhojpur, Bihar-802206 on 25/07/26 (date of inspection) and found that the Mother Teresa Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 year.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

(Signature) 27/07/26
 Aoun Kumar
 अवर प्रमण्डल पदाधिकारी
 लोक स्वास्थ्य अवर प्रमण्डल
 अरा

To

Mother Teresa Public School,
 Dularpur, Ara, Bhojpur, Bihar-
 802206

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

(Signature)
Manager
 Mother Teresa Public School
 Dularpur, Ara, Bhojpur, Bihar

(Signature)
Principal
 Mother Teresa Public School
 Dularpur, Ara, Bhojpur, Bihar

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

District Name :Bhojpur
Sample Collected By : Self

Division Name: P.H. Division, Ara

Date of Sampling :- 13/07/2026
Date of Testing :- 16/07/2026

Sample Collected By: Self						Parameters																	
S	Block	Panchayat	Village	Location of Source	Ward No.	pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As	Total Coli	Remarks		
1	Ara	Nagar Nigam	-	Mother Teresa Public School Dularpur, Ara, Bhojpur (Bihar)	-	6.971	0.3	96	62	72.72	21.04	4.90	39.42	121.2	0.03	NT	NT	NT	<0.001	-ve	Safe		
						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-			
Permissible Limit in absence of alternative source						NR	5	-	2000	600	200	100	1000	500	NR	NR	400	1.5	NR	-			

*NT = Not Tested, BDL=Below Detection Limit


Research Assistant
(Chemist)
P.H. Division, Ara


Manager
Mother Teresa Public School
Dularpur, Ara, Bhojpur, Bihar


Principal
Mother Teresa Public School
Dularpur, Ara, Bhojpur, Bihar